
# Preliminary results from 3D CMS pixel detectors

Ozhan Koybasi, Enver Alagoz, Ryan Rivera, Lorenzo Uplegger, Marcos Turqueti, Kirk Arndt, Daniela Bortoletto, Simon Kwan, et al.




# **3D CMS Pixel Layouts**



#### Four 3D sensors mounted on plaquettes for testbeam:

2E\_WB5\_2 : 2E configuration, 280μm substrate thickness 4E\_WB5\_8 : 4E configuration, 280μm substrate thickness 4E\_WB2-16\_5 : 4E configuration, 200μm substrate thickness 2E\_WB2-16\_2 : 2E configuration, 200μm substrate thickness


# **Assembly**



- Support wafer made wire-bonding challenging (especially high voltage wiring)
- Sensors mounted on carbon fiber plates (0.5 mm thick)
- Cooling was done by a chiller
- Sensor temperature measurement: an RTD placed on the carbon fiber (cooling tubes side):  $\Delta T = 6$  °C


# **I-V Characteristics**

# Measured at room temperature




# **Noise**

- Measured at room temperature
- Unable to measure noise at  $V_{bias}$  < 40V for 4E sensors




# Test beam setup at FNAL




# **Beam Test Results**


Sensor: 2E\_WB5\_2

280µm substrate thickness





- Gain calibration done
- ADC to electron conversion:
  Vcal\* [DAC] = ADC x gain offset
  Charge (e-) = Vcal x 65.5 410
  - \* 1 Vcal [DAC] = 65.5 electrons
- T ≈ 11 °C on carbon fiber (estimated to be 6 °C higher on the sensor)






#### Beam spot on 3D






# **Charge collection**




- Each point is charge distribution mean
- Convoluted Landau and Gaussian fit to be done later
- Bias scan done only at Threshold [DAC] = 50




# **Beam Test Results**

Sensor : 2E\_WB2-16\_6

200µm substrate thickness



- Gain calibration was wrong: it has to be done again
- Detector data still requires further studies



# Summary


- Four 3D sensors received and wire bonded
- Lab characterization done
- 3D sensor assembled for the testbeam
- Sensors tested at FNAL with 120 GeV protons
- Bias and threshold scans performed
- 2Es worked and 4Es failed

# Next:


- Further analysis
- Gain calibration and charge collection with a radioactive source setup at Purdue


# **BACKUP SLIDES**


# Correlation between planes




Sensor: 2E\_WB5\_2









# Sensor: 2E\_WB2-16\_6

